



# ADDENDUM NO. 1

**TO: All Prospective New Wells Collection Lines Material proposers**  
**FROM: Darren Schick**  
**PROJECT NAME: Phase 4 Collection Pipeline materials**  
**DATE: April 9, 2024**

This Addendum consists of   1   page(s):

**I. The acceptable HDPE Pipe pressure class has changed:**

The acceptable HDPE pressure class listed under Additive Alternates 2 & 3 has changed from DR 11 to DR 13.5.

*Receipt of this addendum must be acknowledged by the Proposer, below and on the Proposal. This entire Addendum, or a copy of it, must be attached to the Proposal submitted.*

ACKNOWLEDGED:

By: \_\_\_\_\_

***END OF ADDENDUM NO. 1***